## SIEMENS

## Product data sheet

## 3RT1017-1BB41



CONTACTOR, AC-3 5.5KW/400V, 1NO DC 24 V, 3-POLE, SIZE S00, SCREW CONNECTION

General technical data:						
product brand name		SIRIUS				
Size of the contactor		S00				
Protection class IP / on the front		IP20				
Degree of pollution		3				
Installation altitude / at a height over sea level / maximum	m	2,000				
Ambient temperature / during operating	°C	-25 +60				
Mechanical operating cycles as operating time						
of the contactor / typical		30,000,000				
• of the contactor with added auxiliary switch block / typical		10,000,000				
<ul> <li>of the contactor with added electronics-compatible auxiliary switch block / typical</li> </ul>		5,000,000				
Main circuit:						
Number of NC contacts / for main contacts		0				
Number of NO contacts / for main contacts		3				
Operating current						
• at AC-1 / at 400 V						
• at 40 °C ambient temperature / rated value	А	22				
• at 60 °C ambient temperature / rated value	А	20				
• at AC-3 / at 400 V / rated value	А	12				



• at AC-4 / at 400 V / rated value	А	8.5
• with 1 current path / at DC-1		
• at 24 V / rated value	А	20
• at 110 V / rated value	А	2.1
<ul> <li>with 2 current paths in series / at DC-1</li> </ul>		
• at 24 V / rated value	А	20
• at 110 V / rated value	А	12
<ul> <li>with 3 current paths in series / at DC-1</li> </ul>		
• at 24 V / rated value	А	20
• at 110 V / rated value	А	20
• with 1 current path / at DC-3 / at DC-5		
• at 24 V / rated value	А	20
• at 110 V / rated value	А	0.15
• with 2 current paths in series / at DC-3 / at DC-5		
• at 24 V / rated value	А	20
• at 110 V / rated value	А	0.35
• with 3 current paths in series / at DC-3 / at DC-5		
• at 24 V / rated value	А	20
• at 110 V / rated value	А	20
Service power		
• at AC-2 / at 400 V / rated value	kW	5.5
• at AC-3 / at 400 V / rated value	kW	5.5
• at AC-4 / at 400 V / rated value	W	4,000
Control circuit:		
Type of voltage / of the controlled supply voltage		DC
Operating range factor control supply voltage rated value / of the magnet coil		
• for DC		0.85 1.1
Pull-in power / of the solenoid / for DC	W	3.3
Holding power / of the solenoid / for DC	W	3.3
Auxiliary circuit:		
Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)
Number of NC contacts / for auxiliary contacts / instantaneous switching		0

Number of NO contacts / for auxiliary contacts / instantaneous switching

## Short-circuit:

- Design of the fuse link
  - $\ensuremath{\bullet}$  for short-circuit protection of the auxiliary switch / required

fuse gL/gG: 10 A

1



<ul> <li>for short-circuit protection of the main circuit</li> </ul>		
<ul> <li>with type of assignment 1 / required</li> </ul>		fuse gL/gG: 35 A
• at type of coordination 2 / required		fuse gL/gG: 20 A
Installation/mounting/dimensions:		
Type of mounting		screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 50022
series installation		Yes
Width	mm	45
Height	mm	57.5
Depth	mm	72
Distance, to be maintained, to earthed part / sidewards	mm	6
Connection type:		
Design of the electrical connection		
for main current circuit		screw-type terminals
<ul> <li>for auxiliary and control current circuit</li> </ul>		screw-type terminals
Type of the connectable conductor cross-section		
for main contacts		
• solid		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x (0.75 4 mm²)
finely stranded		
<ul> <li>with conductor end processing</li> </ul>		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
• for AWG conductors / for main contacts		2x (20 16), 2x (18 14), 1x 12
for auxiliary contacts		
• solid		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x (0.75 4 mm²)
• finely stranded		
<ul> <li>with conductor end processing</li> </ul>		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
for AWG conductors / for auxiliary contacts		2x (20 16), 2x (18 14), 1x 12

Certificates/approvals:




General Product Approval							
	(SA)	EAC	GOST	KETI			
Functional Safety / Safety of Machinery	Declaration of Conformity	Test Certificates					
Type Examination	EG-Konf.	other	Special Test Certificate				
Shipping Approval							
ABS	ĴÅ DNV DNV	GL	Llovd's Register	PRS	RINA		
Shipping Approval	other						
RMRS	Confirmation	<u>other</u>	Environmental Confirmations				
Further information:							
Information- and Downloadcenter (Catalogs, Brochures,) http://www.siemens.com/industrial-controls/catalogs							
Industry Mall (Online ordering system) http://www.siemens.com/industrial-controls/mall							
Cax online generator:							

http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3RT1017-1BB41/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...) http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3RT1017-1BB41



12/23/2013





last change:

Aug 12, 2013

