SIEMENS

Data sheet 5SL6350-7



Miniature circuit breaker 400 V 6kA, 3-pole, C, 50 A

Model	
product brand name	SENTRON
product designation	Miniature circuit breaker
General technical data	Williatare direated
number of poles	3
design of pole	3P
	C
tripping characteristic class	10 000
mechanical service life (operating cycles) typical	
overvoltage category	2
degree of pollution	2
Voltage	
type of voltage of the operating voltage	AC
insulation voltage (Ui)	
with multi-phase operation at AC rated value	440 V
Supply voltage	
supply voltage at AC rated value	400 V
value range of the supply voltage frequency	50/60 Hz
operating voltage	
 with multi-phase operation at AC maximum 	440 V
at DC rated value maximum	72 V
Protection class	
protection class IP	IP20, with connected conductors
Switching capacity	
switching capacity current	
 according to EN 60898 rated value 	6 kA
 according to IEC 60947-2 rated value 	6 kA
energy limitation class	3
Dissipation	
power loss [W] for rated value of the current at AC in hot operating state per pole	3.8 W
suitability for operation	Residential buildings/infrastructure
Product details	
product feature	
• halogen-free	Yes
• sealable	Yes
• silicon-free	Yes
product extension installable supplementary devices	Yes
product extension installable supplementary devices	
Connections	

• maximum	25 mm²
connectable conductor cross-section stranded	
• minimum	0.75 mm ²
• maximum	25 mm²
connectable conductor cross-section finely stranded with core end processing	
• minimum	0.75 mm²
maximum	25 mm²
tightening torque with screw-type terminals	
• minimum	2.5 N·m
• maximum	3 N·m
Mechanical Design	
height	90 mm
width	54 mm
depth	76 mm
installation depth	70 mm
number of modular width units	3
mounting position	any
net weight	465 g
Environmental conditions	
ambient temperature during operation	
• minimum	-25 °C
• maximum	45 °C
ambient temperature during storage	
• minimum	-40 °C
• maximum	75 °C
Approvals Certificates	

CEBEC

General Product Approval

Confirmation



firmations





Declaration of Conformity



 Other
 Environment

 Miscellaneous
 Confirmation

 Environmental Con

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SL6350-7

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SL6350-7

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SL6350-7


CAx-Online-Generator


http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications







ARSHOP

8/12/2022



