SIEMENS

Data sheet

6ES7514-2VN03-0AB0



SIMATIC DP, CPU 1514SP T-2 PN for ET 200SP, central processing unit with work memory 900 KB for program and 3.5 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT 6 ns bit performance, SIMATIC Memory Card required, BusAdapter required for 1st interface **** approvals and certificate entry 109817813 at support.industry.siemens.com ****

Figure similar

General information	
Product type designation	CPU 1514SP T-2 PN
HW functional status	FS01
Firmware version	V3.0
• FW update possible	Yes
Product function	
● I&M data	Yes; I&M0 to I&M3
 Module swapping during operation (hot swapping) 	Yes; Multi-hot swapping
Isochronous mode	Yes; only with PROFINET; with minimum OB 6x cycle of 375 μs
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	V18 (FW V3.0)
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	10 ms
Input current	
Current consumption (rated value)	0.51 A
Current consumption, max.	0.7 A
Inrush current, max.	1.34 A; Rated value
l²t	0.3 A ² ·s
Power	
Infeed power to the backplane bus	8.05 W
Power loss	
Power loss, typ.	3.5 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
 integrated (for program) 	900 kbyte
 integrated (for data) 	3.5 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte



Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	6 ns
for word operations, typ.	7 ns
for fixed point arithmetic, typ.	9 ns
for floating point arithmetic, typ.	37 ns
CPU-blocks	
Number of elements (total)	8 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	3.5 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	900 kbyte
FC	
Number range	0 65 535
Size, max.	900 kbyte
OB	
• Size, max.	900 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of time alarm OBs Number of delay alarm OBs	20
Number of delay alarm OBs Number of cyclic interrupt OBs	20 20; With minimum OB 3x cycle of 250 µs
 Number of process alarm OBs Number of DPV1 alarm OBs 	50
	3
Number of isochronous mode OBs	1
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	512 kbyte; In total; available retentive memory for bit memories, timers,
-	counters, DBs, and technology data (axes): 472 KB
Flag	
• Size, max.	
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
 Size, max. Number of clock memories Data blocks Retentivity adjustable 	Yes



Local data	
 per priority class, max. 	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	8 192; max. number of modules / submodules
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	0.0090
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
	o kuyte
Subprocess images	32
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	288 byte; For input and output data respectively
Address space per station	
 Address space per station, max. 	2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	
Number of distributed IO systems	64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	·,····································
• Via CM	1
Number of IO Controllers	
integrated	2
• Via CM	0
Rack	·
Modules per rack, max.	80; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET
	200AL modules
 Quantity of operable ET 200SP modules, max. 	64
Quantity of operable ET 200AL modules, max.	16
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Туре	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
• Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
• to DP, master	Yes; Via CM DP module
• to DP, slave	Yes; Via CM DP module
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	2
Number of PROFIBUS interfaces	1; Via CM DP module
Optical interface	No
1. Interface	
Interface types	
• RJ 45 (Ethernet)	Yes; X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
Number of ports	2; via BusAdapter
integrated switchBusAdapter (PROFINET)	Yes
	Yes; compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x M12



Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
 SIMATIC communication 	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
 — Direct data exchange 	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
- PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
- Number of connectable IO Devices, max.	256; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
- Number of connectable IO Devices for RT, max.	256
— of which in line, max.	256
 — Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
- Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 375 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 µs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3
	875 µs)
Update time for RT	
— for send cycle of 250 μs	250 µs to 128 ms
— for send cycle of 500 μs	500 µs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
- for send cycle of 2 ms	2 ms to 512 ms
- for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes
- PROFlenergy	Yes; per user program
— Shared device	Yes
- Number of IO Controllers with shared device, max.	4
- activation/deactivation of I-devices	Yes; per user program
Asset management record	Yes; per user program
2. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X2
Number of ports	1
integrated switch	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
 SIMATIC communication 	Yes



Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— Direct data exchange	No
— IRT	No
	Yes; per user program
— Prioritized startup	No
— Number of connectable IO Devices, max.	32; In total, up to 1 000 distributed I/O devices can be connected via AS-i,
	PROFIBUS or PROFINET
 — Number of connectable IO Devices for RT, max. 	32
— of which in line, max.	32
 — Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
- Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	No
- PROFlenergy	Yes; per user program
- Prioritized startup	No
— Shared device	Yes
- Number of IO Controllers with shared device, max.	4
- activation/deactivation of I-devices	Yes; per user program
- Asset management record	Yes; per user program
3. Interface	
Interface types	
• RS 485	Yes; Via CM DP module
Number of ports	1
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP slave	Yes
SIMATIC communication	Yes
PROFIBUS DP master	
Number of connections, max.	48; Of which 4 each reserved for ES and HMI
Number of DP slaves, max.	125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
Services	
Services — PG/OP communication	Yes
 — PG/OP communication — Equidistance 	No
 — PG/OP communication — Equidistance — Isochronous mode 	No No
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves 	No
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves 	No No
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet)	No No Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps 	No No Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation 	No No Yes Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation Autocrossing 	No No Yes Yes Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation Autocrossing Industrial Ethernet status LED 	No No Yes Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation Autocrossing Industrial Ethernet status LED RS 485 	No No Yes Yes Yes Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation Autocrossing Industrial Ethernet status LED RS 485 Transmission rate, max. 	No No Yes Yes Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation Autocrossing Industrial Ethernet status LED RS 485 Transmission rate, max. 	No No Yes Yes Yes Yes Yes Yes
 PG/OP communication Equidistance Isochronous mode Activation/deactivation of DP slaves nterface types RJ 45 (Ethernet) 100 Mbps Autonegotiation Autocrossing Industrial Ethernet status LED RS 485 	No No Yes Yes Yes Yes Yes



	400 via interneta distanta era afilia ODU and anno stad ODa (OMa
Number of connections, max.	192; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections reserved for ES/HMI/web	10
Number of connections via integrated interfaces	128
Number of connections per CP/CM	32
Number of S7 routing paths	16
Redundancy mode • H-Sync forwarding	Yes
Media redundancy	103
— Media redundancy	Yes; only via BusAdapter
- MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager;
	MRP Client
- MRP interconnection, supported	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
S7 routing	Yes
Data record routing	Yes
• S7 communication, as server	Yes
• S7 communication, as client	Yes
• User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
- several passive connections per port, supported	Yes
ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; max. 118 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes; "Medium" license required
OPC UA Client	Yes; Data Access (registered Read/Write), Method Call
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
- Number of connections, max.	10
 Number of nodes of the client interfaces, recommended max. 	2 000
 — Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_L max. 	300
 — Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 — Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions for session management, per connection, max. 	1
 Number of simultaneous calls of the client instructions for data access, per connection, max. 	5
- Number of registerable nodes, max.	5 000



OPC_UA_MethodCall, max.	
— Number of inputs/outputs when calling	20
OPC_UA_MethodCall, max.	
OPC UA Server	Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space
 Application authentication 	Yes
— Security policies	available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss
— User authentication	"anonymous" or by user name & password
 — GDS support (certificate management) 	Yes
 Number of sessions, max. 	48
 Number of accessible variables, max. 	100 000
 Number of registerable nodes, max. 	20 000
 Number of subscriptions per session, max. 	50
— Sampling interval, min.	100 ms
— Publishing interval, min.	100 ms
 Number of server methods, max. 	50
 — Number of inputs/outputs per server method, max. 	20
 — Number of monitored items, recommended max. 	4 000; for 1 s sampling interval and 1 s send interval
— Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 Number of nodes for user-defined server interfaces, 	30 000
max.	Vee
Alarms and Conditions	Yes
Number of program alarms	200
— Number of alarms for system diagnostics	100
Further protocols MODBUS	
	Yes; MODBUS TCP
S7 message functions	<u></u>
Number of login stations for message functions, max.	64
Program alarms	Yes
Number of configurable program messages, max.	10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	5 000
Number of simultaneously active program alarms	4 000
Number of simultaneously active program alarms Number of program alarms 	1 000
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics	200
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects 	
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions	200 160
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering)	200 160 Yes; Parallel online access possible for up to 8 engineering systems
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing • Forcing • Forcing • Forcing, variables	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job Peripheral inputs/outputs
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing • Number of variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. 	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs 200
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Beroring • Forcing • Forcing • Forcing, variables • Number of variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Beroring • Forcing • Forcing • Forcing • Regress • Number of variables, max.	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes 3 200
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer of which powerfail-proof 	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes
Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Diagnostic buffer • present • Number of entries, max. — of which powerfail-proof Traces	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes 3 200 500
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer of which powerfail-proof Traces Number of configurable Traces 	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes 3 200
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which status variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer of which powerfail-proof Traces Number of configurable Traces 	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes 3 200 500
Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer of which powerfail-proof Traces Number of configurable Traces 	200 160 Yes; Parallel online access possible for up to 8 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job Yes Peripheral inputs/outputs 200 Yes 3 200 500



• ERROR LED	Yes
MAINT LED	Yes
Monitoring of the supply voltage (PWR-LED)	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
	program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for technology objects 	2 400
 Required Motion Control resources 	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
 Number of available Extended Motion Control resources for technology objects 	120
 Required Extended Motion Control resources 	
— per cam (1 000 points and 50 segments)	2
— per cam (10 000 points and 50 segments)	20
 for each set of kinematics 	30
— Per leading axis proxy	3
 kinematics functions 	
 — kinematics with up to 4 interpolating axes 	Yes; max. 3D + orientation
 — kinematics with 5 or more interpolating axes 	No
 — user-defined kinematics 	No
— SIMATIC Safe Kinematics	No
Positioning axis	
 Number of positioning axes at motion control cycle of 4 ms (typical value) 	11
 Number of positioning axes at motion control cycle of 8 ms (typical value) 	20
Controller	
 PID_Compact 	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-30 °C; No condensation
horizontal installation, max.	00 °C
vertical installation, min.	-30 °C; No condensation
vertical installation, max.	50 °C
Altitude during operation relating to sea level	
Installation altitude above sea level, max.	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	Vec
- LAD	Yes
— FBD	Yes
— STL	Yes
- SCL	Yes
— GRAPH	Yes
Know-how protection	Vec
User program protection/password protection	Yes
Copy protection	Yes
Block protection	Yes
Access protection	Vec
 protection of confidential configuration data 	Yes



 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Complete protection 	Yes
programming / cycle time monitoring / header	
lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	265 g
weight, applox.	205 g

last modified:

10/6/2023 🖸

