SIEMENS

Data sheet

6GK5206-2BF00-2AB2



SCALANCE XB206-2LD managed Layer 2 IE switch 6x 10/100 Mbps RJ45 ports 2x SM FO SC port 1x console port, diagnostics LED redundant power supply; IEC 62443-4-2 certified; temperature range 0 °C to +60 °C; DIN-rail mounting; default PROFINET.

product type designation	SCALANCE	
transfer rate		
transfer rate	10 Mbit/s, 100 Mbit/s	
number of ports / maximum	8	
interfaces / for communication / maximum configuration for modular devices		
number of electrical ports / maximum	6	
number of optical ports / maximum	2	
interfaces / for communication / integrated		
number of electrical connections		
 for network components or terminal equipment 	6; RJ45	
number of 100 Mbit/s ST(BFOC) ports		
 for multimode 	2	
interfaces / other		
number of electrical connections		
 for operator console 	1	
 for management purposes 	1	
 for power supply 	1	
type of electrical connection		
 for operator console 	RJ11	
 for management purposes 	RJ45	
supply voltage, current consumption, power loss		
product component / connection for redundant voltage supply	Yes	
type of voltage / 1 / of the supply voltage	DC	
 supply voltage / 1 / rated value 	24 V	
 power loss [W] / 1 / rated value 	7.2 W	
 supply voltage / 1 / rated value 	19.2 28.8 V	
 consumed current / 1 / maximum 	0.3 A	
 type of electrical connection / 1 / for power supply 	6-pole terminal block	
 product component / 1 / fusing at power supply input 	Yes	
ambient conditions		
ambient temperature		
 during operation 	0 60 °C	
during storage	-40 +70 °C	
during transport	-40 +70 °C	
relative humidity		
 at 25 °C / without condensation / during operation / maximum 	95 %	
protection class IP	IP20	
design, dimensions and weights		
design	Box	



width	80 mm
height	
depth	109 mm
net weight	0.35 kg
material / of the enclosure	 Plastic
fastening method	
35 mm top hat DIN rail mounting	Yes
product features, product functions, product components / ger	
cascading in the case of a redundant ring / at reconfiguration	50
time of <\~0.3\~s	
cascading in cases of star topology	any (depending only on signal propagation time)
product functions / management, configuration, engineering	
product function	
• CLI	Yes
 web-based management 	Yes
MIB support	Yes
TRAPs via email	Yes
 configuration with STEP 7 	Yes
RMON	Yes
• port mirroring	Yes
multiport mirroring	No
• CoS	Yes
PROFINET IO diagnosis	Yes
PROFINET conformity class	В
product function / switch-managed	Yes
telegram length / for Ethernet / maximum	1522 byte
protocol / is supported	
Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• DCP	Yes
• LLDP	Yes
EtherNet/IP	Yes
SNMP v1	Yes
SNMP v2	Yes
• SNMP v3	Yes
 IGMP (snooping/querier) 	Yes
identification & maintenance function	
 I&M0 - device-specific information 	Yes
 I&M1 - higher level designation/location designation 	Yes
product functions / diagnostics	
product function	
 port diagnostics 	Yes
statistics Packet Size	Yes
 statistics packet type 	Yes
error statistics	Yes
• SysLog	Yes
 loopback diagnostics 	Yes
product functions / VLAN	
product function	
VLAN - port based	Yes
product functions / DHCP	
product function	
DHCP client	Yes
product functions / redundancy	
product function	
ring redundancy	Yes
High Speed Redundancy Protocol (HRP)	Yes
 high speed redundancy protocol (HRP) with redundancy 	Yes
high opera reachancy protocol (That) wanted and alloy	



9/6/2023

managar	
manager	Vee
 high speed redundancy protocol (HRP) with standby redundancy 	Yes
protocol / is supported / Media Redundancy Protocol (MRP)	Yes
product function	
media redundancy protocol (MRP) with redundancy	Yes
manager	
 Media Redundancy Protocol Interconnection (MRP-I) 	Yes
redundancy procedure STP	Yes
redundancy procedure RSTP	Yes
 redundancy procedure RSTP+ 	Yes
Parallel Redundancy Protocol (PRP)/operation in the	No
PRP-network	NU
passive listening	Yes
protocol / is supported	
• LACP	Yes
product functions / security	
product function	
•	Voc
ACL - MAC-based	Yes
ACL - port/MAC-based	Yes
• IEEE 802.1x (radius)	Yes
 broadcast/multicast/unicast limiter 	Yes
broadcast blocking	Yes
protocol / is supported	
• SSH	Yes
• SSL	Yes
product functions / time	
product function	
SICLOCK support	Yes
NTP-client	Yes
SNTP client	Yes
protocol / is supported	
protocol / is supported • SNTP	Yes
• SNTP	Yes
SNTP standards, specifications, approvals	Yes
SNTP standards, specifications, approvals standard	
SNTP standards, specifications, approvals standard for FM	In preparation
SNTP standards, specifications, approvals standard for FM for emitted interference	In preparation EN 61000-6-4 (Class A)
SNTP standards, specifications, approvals standard o for FM o for emitted interference o for interference immunity	In preparation EN 61000-6-4 (Class A) EN 61000-6-2
SNTP standards, specifications, approvals standard for FM for emitted interference	In preparation EN 61000-6-4 (Class A)
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC	In preparation EN 61000-6-4 (Class A) EN 61000-6-2
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019	In preparation EN 61000-6-4 (Class A) EN 61000-6-2
SNTP standards, specifications, approvals standard o for FM o for emitted interference o for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes
SNTP standards, specifications, approvals standard • for FM • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code • according to IEC 81346-2 • according to IEC 81346-2:2019	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes Yes
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX
SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C,
SNTP Standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standard / for hazardous zone from CSA and UL 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C,
SNTP Standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standard / for hazardous zone from CSA and UL 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C,
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standard / for hazardous zone from CSA and UL certificate of suitability 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes Ex nA IIC T4 Gc
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard of CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes Yes 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7)
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability CcTick 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4 Yes
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability Cut y HazLoc / as File Nr. 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4
 SNTP standards, specifications, approvals standard for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability Curc / cor suitability 	In preparation EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T7, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4 Yes



9/6/2023

 to web page: selection aid TIA Selection Tool 	http://www.siemens.com/tia-selection-tool
 to website: Industrial communication 	http://www.siemens.com/simatic-net
• to website: Industry Mall	https://mall.industry.siemens.com
 to website: Information and Download Center 	http://www.siemens.com/industry/infocenter
• to website: Image database	http://automation.siemens.com/bilddb
 to website: CAx-Download-Manager 	http://www.siemens.com/cax
to website: Industry Online Support	https://support.industry.siemens.com
security information	
security information	Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

8/11/2023 🖸

