SIEMENS

Data sheet

6GK5216-0BA00-2AB2

Product type designation

Product description



SCALANCE XB216

Preset for PROFINET mode!
SCALANCE XB216 MANAGEABLE LAYER 2 IE-SWITCH 16X
10/100 MBITS/S RJ45 PORTS 1X KONSOLEN-PORT
DIAGNOSTICS-LED REDUNDANT POWER SUPPLY TEMP.RANGE 0 DGR C UP TO DIN RAIL MOUNTING PROFINET IODEVICE ETHERNET/IP-CERTIFICATE DEFAULT PROFINET

Transmission rate	
Transfer rate	10 Mbit/s, 100 Mbit/s
Interfaces / for communication / integrated	
Number of electrical connections	
 for network components or terminal equipment 	16
Interfaces / others	
Number of electrical connections	
 for operator console 	1
for management purposes	1
• for power supply	1
for redundant voltage supply	1
Type of electrical connection	
• for operator console	RJ11 port
for management purposes	RJ45 port
• for power supply	6-pole terminal block

Page 1/5

Supply voltage, current consumption, power loss

DC
24 V
19.2 28.8 V
Yes
0.28 A

Permitted ambient conditions	
Ambient temperature	
during operation	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
Relative humidity	
 at 25 °C / without condensation / during operation / maximum 	95 %
Protection class IP	IP20

Design, dimensions and weight	
Design	compact
Width	80 mm
Height	117 mm
Depth	109 mm
Net weight	0.4 kg
Material / of the enclosure	Plastic
Mounting type	
• 35 mm DIN rail mounting	Yes
wall mounting	No
• S7-300 rail mounting	No
• S7-1500 rail mounting	No

Product properties, functions, components / general	
Cascading in the case of a redundant ring / at	50
reconfiguration time of <\~0.3\~s	
Cascading in cases of star topology	any (depending only on signal propagation time)

Product functions / management, configuration Product function Yes • CLI Yes • web-based management Yes • MIB support Yes • TRAPs via email Yes • Configuration with STEP 7 Yes • RMON Yes • Port mirroring No • multiport mirroring



• CoS	Yes
with IRT / PROFINET IO switch	No
PROFINET IO diagnosis	Yes
switch-managed	Yes
Telegram length / for Ethernet / maximum	1522 byte
Protocol / is supported	
● Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• BOOTP	No
• DCP	Yes
• LLDP	Yes
• EtherNet/IP	Yes
• IGMP (snooping/querier)	Yes
Identification & maintenance function	
 I&M0 - device-specific information 	Yes
 I&M1 – higher-level designation/location designation 	Yes
Protocol / is supported	
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
Product functions / Diagnosis	
Product function	
 Port diagnostics 	Yes
Statistics Packet Size	Yes
Statistics packet type	Yes
Error statistics	Yes
SysLog	Yes
 loopback diagnostics 	Yes
Product functions / VLAN	
Product function	
 VLAN - port based 	Yes
 VLAN - protocol-based 	No

Product functions / DHCP

• VLAN dynamic

• VLAN - IP-based

Product function



No No

Droduct functions / Deductions	
Product functions / Redundancy Product function	
Ring redundancy	Yes
High Speed Redundancy Protocol (HRP)	Yes
	Yes
 high speed redundancy protocol (HRP) with redundancy manager 	res
 high speed redundancy protocol (HRP) with standby redundancy 	No
Protocol / is supported / Media Redundancy Protocol (MRP)	Yes
Product function	
 media redundancy protocol (MRP) with redundancy manager 	Yes
• redundancy procedure STP	Yes
• redundancy procedure RSTP	Yes
• redundancy procedure MSTP	Yes
 Parallel Redundancy Protocol (PRP)/operation in the PRP-network 	No
 Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA) 	No
Passive listening	Yes
Product functions / Security	
Product function	
• IEEE 802.1x (radius)	Yes
 Broadcast/Multicast/Unicast Limiter 	Yes
 broadcast blocking 	Yes
Protocol / is supported	
• SSH	Yes
Product functions / Time	
Product function	
 SICLOCK support 	Yes
Protocol / is supported	
• NTP	Yes
• SNTP	Yes
Standards, specifications, approvals	
Standard	FM2044, Close 4, Divisor 2, Crow A, B, C, D, (T4, Cl. 4, 7, 1)
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T8
• for hazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA



• for safety / from CSA and UL

UL 60950-1, CSA C22.2 No. 60950-5

07 ATEX 0145X

ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / • for hazardous zone / from CSA and UL GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8 • for emitted interference EN 61000-6-4 (Class A) EN 61000-6-6 • for interference immunity Certificate of suitability / CE marking Yes EN 61000-6-2, EN 61000-6-8 Certificate of suitability C-Tick No Railway application in accordance with EN 50155 No • Railway application in accordance with EN

Yes

Further Information / Internet Links

Internet-Link

50124-1

KC approval

• to website: Selector SIMATIC NET SELECTION TOOL

• to website: Industrial communication

• to website: Industry Mall

• to website: Information and Download Center

• to website: Image database

• to website: CAx Download Manager

• to website: Industry Online Support

http://www.siemens.com/snst

http://www.siemens.com/simatic-net

https://mall.industry.siemens.com

http://www.siemens.com/industry/infocenter

http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

Security information

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Thirdparty products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

07/07/2016